



District Level Water Analysis Laboratory,
Uttar Pradesh Jal Nigam, (Rural), Kalichabad Sultanpur road
District- Jaunpur - 222002

Format No.-7.5 F- 01

TEST REPORT

Report No.	JNP/26/760	Date - 12/05/2026	S. No -760	Page No. 1	Page 1/1
Customer Details					
Office Name and Address	CHANDRABHAN INTERNATIONAL ACADEMY				
Ref Letter No & Date	NA				
Basic Details of sample					
District	JAUNPUR	Block	JALALPUR		
Gram Panchayat	TRILOCHAN BAZAR	Village	TRILOCHAN BAZAR		
Habitation	SCHOOL	Location	TRILOCHAN BAZAR		
Water Source	RO	Sample No.	JNP/26/760		
Quantity of Sample	1000 ml	Date of S.C.	04/05/2026		
Receiving Date	04/05/2026	S. Collector	TESUL AHMAD		
Sample Depositor	TESUL AHMAD	Sampling Method -	IS3025 (Part 1)		
Analysis Start Date	05/05/2026	Analysis Complete Date	05/05/2026		
Environmental Condition					
Temperature	25 ± 3 °C		Relative Humidity	50±15%	
Technical Data of Analysis					
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
	2	3	4	5	6
1	pH @25°C	7.82	6.5	8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	0.69	1	5	IS 3025 (Part 10): 1984: 2021 (Nephelometric method)
3	Total Dissolved Solids (mg/L)	119.8	500	2000	IS 3025 (Part 16): 1984: 2023 (Gravimetric method)
4	Chloride (mg/L)	57	250	1000	IS 3025 (Part 32): 1988: 2021 (Argentometric method)
5	Total Alkalinity (mg/L)	28	200	600	IS 3025 (Part 23): 1986: 2021 (Potentiometric and indicator method)
6	Total Hardness (mg/L)	56	200	600	IS 3025 (Part 21): 2009: 2021 (EDTA method)
7	Calcium (mg/L)	8.8	75	200	IS 3025 (Part 40): 1991: 2019 (EDTA Titrimetric method)
8	Magnesium (mg/L)	8.5	30	100	IS 3025 (Part 46): 1994: 2019 (Volumetric method)
9	Sulphate (as SO ₄)	10.32	200	400	APHA 24th Edition - 4500-SO ₄ Method E (Turbidimetric Method, 2023)
10	Nitrate (as NO ₃) mg/L	7.63	45	No relaxation	APHA 24th Edition - 4500-NO ₃ Method B (UV Screening Method, 2023)
11	Fluoride (as F) mg/L	0.241	1.0	1.5	APHA 24th Edition- 2023, 4500-F (C. Ion Selection Electrode Method)
12	Iron (as Fe) mg/L	BDL	1.0	No relaxation	APHA 24th Edition - 3500- Fe Method B (Phenanthroline, 2023)
Note: -					
1. This certificate refers only to the particular sample (S) submitted for testing.					
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.					
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.					
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.					
5. This report valid for submitted sample only.					
Report View by <u>Rupa Mishra</u> Lab Assistant Manager					
Laboratory Contact details-Email- districtlabjaunpur@gmail.com					
Mob- 8127284974					

End of Test Report

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 26.05.26

It is certified that an inspection team headed by Dr. Samam Yeema,
Medical officer (Name of Officers with designation) from

PHED inspected the CHANDRABHAN INTERNATIONAL ACADEMY, TRILOCHAN BAZAR,
 JAUNPUR, PIN CODE- 222136 (Name & Address of the school) on 26.05.26

(date of inspection) and on the basis of Water Test Report (Attached) bearing no. JNP/26/760

dated 12/05/2026 of District Level Water Analysis Laboratory, Uttar Pradesh Jal Nigam,

(Rural), Kalichabad, Sultanpur Road, District- Jaunpur- 222002 (PHED, Lab)


certified that the CHANDRABHAN INTERNATIONAL ACADEMY (Name of school) has

safe drinking water facilities for the students and members of staff of the institution. School also

maintains the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with Seal: 

Name : Dr. Samam Yeema

Designation : Medical officer

Name & Address of the Office / Department :

चिकित्सा अधिकारी
 सामु. स्वा. केन्द्र-रेहटी
 जलालपुर, जौनपुर

To

CHANDRABHAN INTERNATIONAL ACADEMY

Trilochan Bazar, Tehsil- Kerakat

District- Jaunpur- 222136

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies